

## 55. Lighting Ergonomics (A Case Study towards Energy Conservation)

Atif Iqbal<sup>a,\*</sup>

<sup>a</sup>DM, BWL, Karachi-75100, Pakistan

\*E-mail address: atifnedian33@gmail.com, Tel.: +92-333-2182144

---

### Abstract

Energy crises is getting worse situation in the developing countries. Measurements are being taken but they will take some time to overcome the power shortage. Besides these measures, Energy efficiency and conservation are one of the easiest and effective ways to minimize energy consumption hence reducing the power shortage. Among various energy consuming devices, Lighting constitutes a large but necessary portion of the electrical load in most facilities. Appropriate usage of lighting will not only minimize power shortage but also it gives pleasure and comfort to human sight.

This paper presents the detailed study of lighting system of HIET, Hamdard University, and proposed the efficient solution according to the illumination level needed for different classes of visual task as a case study. This paper also proposed the guidelines that will help the energy policy makers in establishing future energy conservative policy.

© 2016 Atif Iqbal<sup>a</sup>. Selection and/or peer-review under responsibility of Energy and Environmental Engineering Research Group (EEERG), Mehran University of Engineering and Technology, Jamshoro, Pakistan.

**Keywords:** " Energy Policy; Energy Efficiency; Energy Conservation; Lighting System ;"

---

### 1. Introduction:

In the developing countries, where there is a gap between demand and supply, measures are being taken for reduction in electricity consumptions as a part of their demand side management. Among the different techniques for reduction in power consumption, replacement of energy inefficient lamps with energy efficient lamp is also one of them. [1].

In this paper, the comparison of performance of Linear Fluorescent tube lights (FL), Compact fluorescent lamps (CFL) and LED lamps on the basis of power consumption, lumens and lamp cost has been presented. HIET, Hamdard University Karachi was selected as case study and analysis of energy consumption in lighting with respect to recommended illumination level for various types of activities is confronted in this work.

This paper has been prepared on the measurements recorded & the data collected, compiled & recorded from initial months of 2015. The main focus of this study is to develop understanding and awareness among people in general of the nation to adopt latest energy management and conservative polices to overcome energy shortage of the country

The details are discussed in future sections.

### 2. Lighting Systems

Proper lighting makes all work tasks easier, whether in industrial or office settings. People receive about 85% of their information through their sense of sight. Appropriate lighting, without glare or shadows, can reduce eye fatigue and headaches; it can prevent workplace accidents by increasing the visibility of moving machinery and other safety hazards. Good quality lighting also reduces the chance of accidents and injuries from momentary blindness. [2]

### 3. HIET Electrical Energy Measurement

Initially a walk through audit of the building was conducted to identify the areas for energy conservation. Assessment of illumination requirement of the building and scope of improvement of illumination quality with an objective to reduce cost was also conducted.

HIET is an educational institute consisting of different sections e.g. conference room, class rooms, laboratories, workshops, library, canteen and offices. Total HIET electrical load is estimated to be **366kW**.

The layout of electrical appliances in a class room of HIET, Hamdard University is shown in the Fig. 1.




Fig.-1: Layout of Electrical Appliances in a class room

### 4. Lighting System at HIET Building

Lighting system of HIET, Hamdard University is 16% of the total electrical energy consumption as shown in Fig.-2.




Fig.-2: Percentage wise Electrical Energy Consumption by lighting system Vs. Rest of Appliances in HIET




Fig. 3: Percentage wise Light Energy Consumption at HIET

## 5. Measuring Units Light Level – Illuminance [3]

Illuminance is measured in foot candles (*ftcd, fc, fcd*) (or *lux* in the metric SI system). A *foot candle* is actually *one lumen of light density per square foot*; *one lux* is *one lumen per square meter*.

### 5.1. Calculating Illumination [3]

Illumination is calculated as

$$I = L_l C_u L_{LF} / A_l \quad (1)$$

Where

$I$  = illumination (lux, lumen/m<sup>2</sup>)

$L_l$  = lumens per lamp (lumen)

$C_u$  = coefficient of utilization

$L_{LF}$  = light loss factor

$A_l$  = area per lamp (m<sup>2</sup>)

#### 5.1.1. Light Loss Factor

The equation to determine LLF is simple: [4]

$$LLF = (LLD) (LDD) (BF)$$

Where;

**LLD=Lamp Lumen Depreciation.** LLD is determined by dividing mean, or average, lamp lumens by the initial lumen value.

**LDD=Luminaire Dirt Depreciation.** LDD is a factor relating to how dirty an environment is, and how much it affects the performance of a luminaire.

BF=Ballast Factor.

Higher LLFs = lower system cost, energy savings, but also potential for insufficient lighting  
Lower LLFs = increased energy use, over lighting, glare etc.[5]

So, Light loss factor (LLF) of different devices are as under. [6]

Appliances	LLF
25W T8 Linear Fluorescent	0.73
32W T8 Linear Fluorescent	0.75
26W CFL	0.77
LED Lights [7]	0.85

### 5.1.2 Coefficient of Utilization

The coefficient of utilization is defined as the percentage of lamp lumens reaching a work plane. Due to the cylindrical design of a fluorescent tube lamp, only ~1/3 of the light output directly illuminates the intended surface. Thus the total zonal lumens from 0 to 120 degrees average 65 percent. An LED is a directional light source. Most of the light is contained within a beam angle of 120 degrees, providing light where it's needed. A photometric data comparison validates this effect. [8]

So, Coefficient of Utilization (CU) of different devices are as under

Appliances	CU
Linear Fluorescent Tube light [8]	0.65
LED Lamps [8]	0.86
CFL [9]	0.54

### 5.2. Calculation of Illuminance of Current Linear Fluorescent Tube Lights and CFL and Proposed LED Lights

Consider Junior Faculty room,  
Area is  $12 \times 7 = 84 \text{ m}^2$   
Power of each Tube light = 36W  
No. Of tube lights = 36  
Total Wattage =  $36 \times 36 = 1296 \text{ W}$   
Per Tube light lumens = 80  
Total lumens spread in room =  $1296 \times 80 = 103680$   
So lux is (CU=0.65, LLF=0.75)  
 $I = L_l C_u L_{LF} / A_l$   
 $I = 103680 \times 0.65 \times 0.75 / 84$   
 $I = 602$

The Existing lux measurements of various sections were also verified by using light intensity instrument, "lux meter"

For junior faculty room, we need 500 lux [Table2]

In this way, rest of the sections have been evaluated and Lux calculated as shown in table 1

**Table: 1. Current Lighting illumination levels at various Sections of HIET**

Sections	Area (Sq. m)	Appliance(s)	Tube light Lumens/Watt	Total Lumens	Lux (Lumen/sq..m)	Recommended Lux	Comment on Illumination Level
Junior Faculty-1	84	Tube Light	80	103680	602	500	Ok
Junior Faculty-2	84	Tube Light	80	103680	602	500	Ok
Senior Faculty-1	84	Tube Light	110	126720	735	500	Ok
Senior Faculty-2	84	Tube Light	110	71280	414	500	Not Ok

Reception Area/Ground Floor	42	Tube Light	110	11880	138	200	Not Ok
Reception Area First Floor	42	Tube Light	110	15840	184	200	Not Ok
Reception Area Second Floor	42	Tube Light	110	15840	184	200	Not Ok
HIET Library	336	Tube Light	80	288000	418	300	Ok
Director Office	84	Tube Light	80	69120	401	500	Not Ok
Admin Office	84	Tube Light	80	69120	401	500	Not Ok
Registration Office	42	Tube Light	80	5760	67	500	Not Ok
Dining Room ground floor	42	Tube Light	80	34560	401	200	Ok
Kitchen ground floor	42	Tube Light	80	2880	33	500	Not Ok
Bathrooms	54	Tube Light	110	126720	143	150	Not Ok
Examination Office	84	Tube Light	80	17280	100	500	Not Ok
Research Lab	84	Tube Light	110	63360	368	750	Not Ok
Classrooms A, B, C, D, E, F, G, H, J, K, L, M, P	84	Tube Light	80	1123200	501	300	Ok
Classrooms I, O, N	84	Tube Light	80	103680	201	300	Not Ok
Classrooms R, Q, T, S & girls common room	42	Tube Light	110	79200	184	300	Not Ok
Programming Lab 1 & 2	336	Tube Light	80	144000	209	500	Not Ok
Programming Lab 3	84	Tube Light	80	86400	501	500	Ok
Dirt Lab & SnS Lab	84	Tube Light	80	120960	702	500	Ok
Thermo Lab	84	Tube Light	80	34560	201	500	Not Ok
Labs (BE, MPES, EDC, Physics, Bio, ICE, CE, DCCN, E&N, Environmental)	84	Tube Light	80	864000	501	750	Not Ok
HIESS Faculty-1	84	Tube Light	110	71280	414	500	Not Ok
HIESS Faculty-2	84	Tube Light	110	71280	414	500	Not Ok
Library First Floor	84	Tube Light	80	43200	251	300	Not Ok
Server Room	42	Tube Light	110	63360	735	500	Ok
Computer Hardware room	42	Tube Light	80	11520	134	500	Not Ok
Server Room Ext	42	Tube Light	110	95040	1103	500	Ok
Staircase & corridor	1062	CFL	50	120750	178	100	Ok
Stair case & Corridor (Ext)	1062	CFL	50	331200			
Conference Room	84	CFL	50	16800	83	300	Not Ok

## 6. Comfortable Illumination Levels [10]

These levels are usually measured on a working surface in the building.

**Table 2. Recommended Lighting Levels [10]**

Type of Activity	Characteristics of Activity	Standard Maintained Illuminance (lux)
Cable tunnels, nighttime sidewalk, parking lots	<b>Interiors rarely used for visual tasks</b> (no perception of detail)	50
Corridors, changing rooms, loading bay	<b>Interiors with minimal demand for visual acuity</b> (limited perception of detail)	100 - 150
Foyers and entrances, dining rooms, warehouses, restrooms	<b>Interiors with low demand for visual acuity</b> (some perception of detail)	200

Libraries, sports and assembly halls, teaching spaces, lecture theaters	<b>Interior with some demand for visual acuity</b> (frequently occupied spaces)	300
Computer work, reading & writing, general offices, retail shops, kitchens	<b>Interior with moderate demand for visual acuity</b> (some low contrast, color judgment tasks)	500
Drawing offices, chain stores, general electronics work	<b>Interior with demand for good visual acuity</b> (good color judgment, inviting interior)	750
Detailed electronics assembly, drafting, cabinet making, supermarkets	<b>Interior with demand for superior visual acuity</b> (accurate color judgment & low contrast)	1000
Hand tailoring, precision assembly, detailed drafting, assembly of minute mechanisms	<b>Interior with demand for maximum visual acuity</b> (low contrast, optical aids & local lighting will be of advantage)	1500 -2000+

**Table: 3. Lumen Output: Comparing LED Vs Linear Fluorescent Lamps Wattage [11]**

Column 1	Costs	Payback	Life	Efficiency
T-8 LED Tube light	Rs. 1600-2000	3-4 years	10-15 years	About 110-120 lumens per watt
T-5 Fluorescent Tube light	Rs. 500	6 months to 01 year	3-4 years	110 lumens per watt
T-8 Fluorescent Tube light (Regular Fluorescent)	Rs. 100	-	3-4 years	60-80 lumens per watt (lower for one with electromagnetic ballast)

**Table-4: Lumen Output: Comparing LED vs. CFL vs. Incandescent Wattage [12, 13]**

Light Output	Light Emitting Diodes (LEDs)	Incandescent Light Bulbs	Compact Fluorescents (CFLs)
Lumens	Watts	Watts	Watts
450	4-5	40	9-13
800	6-8	60	13-15
1100	9-13	75	18-25
1600	16-20	100	23-30
2600	25-28	150	30-55

## 7. Factors affecting the amount of light [14]

Quantity of number of LED lights required per room also depends on following factors:

- **Colour shade:** Dark shade of wall requires more lights
- **Height of ceiling:** More heights require more lights.
- **Objects:** Lots of furniture, display items, complex geometry requires more lights.
- **Wastage:** Light very close to wall will waste more amount of light by reflection. You have to install more lights in this case
- **Amount:** More small lights distributed in room can give good illumination than one big light.

## 8. Identifying Energy Management Opportunities (EMO's) Proposed Replacement with LED

Considering LED lights: A typical LED light gives provide 100-120 Lumens per watt [11], let's consider 100 lumens.

Area is  $12 \times 07 = 84 \text{ m}^2$

No. Of proposed LED tube lights= 36 (same quantity with mean gap)

CU=0.86, LLF=0.85

Lumens needed

$$L_l = I A_l / C_u L_{LF}$$

Total lumens spread in room=57456

Total watt needed in room =57456/ (100lumens/watt)

Watt per LED lamp in replacement of same quantities of linear fluorescent tube light=Total watt/no. of LED=574.56/36=**16Watt LED Lamp**

In this way, rest of the sections have been evaluated and Wattage of Lamps calculated as shown in table:  
5




Fig. 4: Comparison graph showing difference in Energy Cost (in PKR.) per month before and after EMO and using recommended illumination level as required by different sections. Black colour corresponds to Energy costs before EMO, and white colour represents Energy cost after EMO and using recommended illumination level

Table 5: After selected recommended illumination levels and using EMO

Sections	Area (Sq. m)	Appliance(s)	LED Tube light Lumens/Watt	Recommend Lux	Total Lumens needed for section	Total Watt	Wattage/ LED Tube light
Junior Faculty-1	84	LED Tube light	100	500	57456	575	16
Junior Faculty-2	84	LED Tube light	100	500	57456	575	16
Senior Faculty-1	84	LED Tube light	100	500	57456	575	9
Senior Faculty-2	84	LED Tube light	100	500	57456	575	16
Reception Area/Ground Floor	42	LED Tube light	100	200	11491	115	19
Reception Area First Floor	42	LED Tube light	100	200	11491	115	14
Reception Area Second Floor	42	LED Tube light	100	200	11491	115	14
HIET Library	336	LED Tube light	100	300	137893	1379	14
Director Office	84	LED Tube light	100	500	57456	575	24
Admin Office	84	LED Tube light	100	500	57456	575	24
Registration Office	42	LED Tube light	100	500	28728	287	144
Dining Room ground floor	42	LED Tube light	100	200	11491	115	10

4<sup>th</sup> International Conference on  
Energy, Environment and Sustainable Development 2016 (EESD 2016)



Kitchen ground floor	42	LED Tube light	100	500	28728	287	287
Bathrooms	54	LED Tube light	100	150	88646	886	14
Examination Office	84	LED Tube light	100	500	57456	575	96
Research Lab	84	LED Tube light	100	750	86183	862	27
Classrooms A, B, C, D, E, F, G, H, J, K, L, M, P	84	LED Tube light	100	300	448153	4482	11
Classrooms I, O, N	84	LED Tube light	100	300	103420	1034	29
Classrooms R, Q, T, S & girls common room	42	LED Tube light	100	300	86183	862	22
Programming Lab 1 & 2	336	LED Tube light	100	500	229822	2298	46
Programming Lab 3	84	LED Tube light	100	500	57456	575	19
Dirt Lab & SnS Lab	84	LED Tube light	100	500	57456	575	14
Thermo Lab	84	LED Tube light	100	500	57456	575	48
Labs (BE, MPES, EDC, Physics, Bio, ICE, CE, DCCN, E&N, Environmental)	84	LED Tube light	100	750	861833	8618	29
HISS Faculty-1	84	LED Tube light	100	500	57456	575	16
HISS Faculty-2	84	LED Tube light	100	500	57456	575	16
Library First Floor	84	LED Tube light	100	300	34473	345	23
Server Room	42	LED Tube light	100	500	28728	287	9
Computer Hardware room	42	LED Tube light	100	500	28728	287	72
Server Room Ext	42	LED Tube light	100	500	28728	287	6
Staircase & corridor	1062	CFL	100	100	145280	1453	3
Conference Room	84	CFL	100	300	34473	345	25